

# Zertifikat *Certificate*

**Zertifikatsnummer Certificate No.:**

R 60175598 0001

**Berichtsnummer Report No.:**

TR248Q4Q 001

**Genehmigungsinhaber License Holder:**

TP ELEKTRİK MALZEMELERİ SAN. VE TİC.

A.Ş

KEMALPASA OSB

MAHALLESİ 600 SOK. NO:364

35730 İZMİR

Türkiye

**Fertigungsstätte Manufacturing Site:**

TP ELEKTRİK MALZEMELERİ SAN. VE TİC.

A.Ş

KEMALPASA OSB

MAHALLESİ 600 SOK. NO:364

35730 İZMİR

Türkiye

**Prüfzeichen Test Mark:**


Type Approved  
Safety  
Regular Production  
Surveillance

www.tuv.com  
ID 1111282395

**Geprüft nach Tested according to:**

IEC 60998-1:2002

IEC 60998-2-1:2002

**Geräteidentifikation**
**Product Identification**
**Produkt:**

Terminal blocks

**Product:**

(Screw Type Terminal Block)

**Modell:**

Modelle sind auf nächste(r) Seite(n) gelistet

**Type:**

Type designation(s) are listed on the next page(s)

**Technische Daten:**

Technische Daten sind auf nächst(r) Seite(n) gelistet.

**Technical Data:**


Technical Data are listed on the next page(s)

**Gültig ab:**

2024-03-20

**Valid from:**
**Zertifizierungsstelle:**
**Certification body:**
**Ausstellungsdatum:**

2024-03-20

**Date of issue:**


Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

**TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg**

<http://www.tuv.com/safety> E-mail: [markcheck@tuv.com](mailto:markcheck@tuv.com)

Fax: +49 221 806-3935

[www.tuv.com](http://www.tuv.com)

 **TÜVRheinland®**  
Precisely Right.

# Zertifikat *Certificate*

**Zertifikatsnummer** *Certificate No.:*

R 60175598 0001

**Berichtsnummer** *Report No.:*

TR248Q4Q 001

**Produkt** *Product:* Terminal blocks  
(Screw Type Terminal Block)**Modell** *Type:* **Bezeichnung** *Designation:*

3197-150-0000

Trademark : tp electric

Rated Voltage : 450VAC

Rated Connecting  
Capacity (mm<sup>2</sup>) : 2,5 mm<sup>2</sup>Glow-wire flammability  
index (GWFI) : 850°C